

### ACTIVITY: ELECTRICITY CARRYING OUT ELECTRICAL WORK

#### Match sentence beginnings and ends

#### Resources:

- Information from the WorkSafe Smart Move Electrical and Electronics Module available from WorkSafe's website at [www.docep.wa.gov.au](http://www.docep.wa.gov.au)

#### Task:

- Match the sentence beginnings and ends.

1. A "deadman" switch	a qualified electrical worker at all times.
2. Working safely with electricity includes the work procedures,	is designed to immediately switch the current off when electricity leaking to earth is detected at a level harmful to a person using electrical equipment.
3. Electrical work should legally only be carried out by	electrical arcing and flying objects.
4. A residual current device	bracelets, rings, neck chains, exposed metal zips or watches.
5. Apprentices and trainees must be supervised by	the type of tools used and the type of clothing worn.
6. Safety glasses provide protection from	the level of voltage they are able to insulate against.
7. Rated insulated gloves are designed for live work and are rated according to	fix appropriate tags, test the electricity supply is isolated and always test your instruments.
8. Safety helmets provide protection from	a licensed electrical worker.
9. While carrying out electrical work near live electrical equipment you should not wear	is designed so the current switches off and the machine stops, when the operator releases pressure on the switch, handle or pedal.
10. Before you start electrical work, you should switch off, isolate circuits,	overhead wires, structures and falling objects.

# WORKSAFE SMART MOVE 2002



Department of Consumer  
and Employment Protection  
Government of Western Australia



Copies of this publication may be freely printed and distributed provided that the WorkSafe division of the Department of Consumer and Employment Protection receives appropriate acknowledgement.